NOTIFICATION

(Law Department)

No. LAW 129 LOR 65, Bangalore, dated 3rd August 1965.

Ordered that the accompanying Notification No G. S. R. 795, dated 21st May 1965 of the Ministry of Irrigation and Power regarding the Indian Electricity (Amendment) Rules, 1965, which has been published in the *Gazette of India*, Part II, Section 3, sub-section (i) dated the 5th June 1965 be republished in the *Mysore Gazette*, for general information.

By Order and in the name of the Governor of Mysore,

101 B. Ramachandra Rao, *Under Secy*

GOVERNMENT OF INDIA

MINISTRY OF IRRIGATION AND POWER

(Central Electricity Board)

New Delhi, the 21st May 1965.

G.S.R. 795.—In exercise of the powers conferred by section 37 of the Indian Electricity Act, 1910 (9 of 1910), the central Electricity Board hereby makes the following rules further to amend the Indian Electricity Rules, 1956, the same having been previously published as required by sub-section (1) of section 38 of the said Act, namely:

1. These rules may be called the Indian Electricity (Amendment) Rules, 1965.

2. In the Indian Electricity Rules 1956—

(i) for rule 10, the following rule shall be substituted, namely :—

"10. *List of Consumers.*—An Inspector may require a supplier to submit to him a list of all persons supplied with energy by him, the addresses at which such energy is supplied, the month of connecting services the voltage of supplyd, the connected load, the purpose of supply and the name of contractor carrying out the installation work and the supplier shall comply with such requisition."

(2) after rule 44, the following rule shall be inserted, namely:—

"44A. *Intimation of accidents.*—A notice of the occurrence of any accident in connection with generation, transformation, transmission, conversion, distribution, supply or use of energy shall be forwarded to the Inspector and other authorities referred to in section 33 in the form set out in Annexure XIII and in accordance with the following procedure, namely:—

(i) In the case of an accident which results in the death of a person, either the person responsible for the generation, transformation, transmission, conversion, distribution, supply or use of energy or any other person authorised by the State Electricity Board in this behalf, shall—

(*a*) within twentyfour hours of the knowledge of occurrence of the accident, send a telegraphic report of the occurrence of such accident to the Inspector and later send a written statement in the prescribed form within twentyfour hours of sending the telegraphic report;

(*b*) send a copy of the written statement in the prescribed form to the Secretary to the appropriate Government in the Department concerned: and

(*c*) within three hours of the coming to his knowledge of the accident, send a report of the occurrence of the accident to the District Magistrate having jurisdiction over the area in which the accident has occurred and to the officer in charge of the nearest Police Station.

(ii) In the case of an accident which results in the death of an animal or disablement, of a person, either the person responsible for the generation, transformation, transmission, conversion distribution, supply or use of energy or any other person authorised by the State Electricity, Board in this behalf, shall within twentyfour hours of the knowledge of occurrence of such accident send a telegraphic report of the occurrence of such accident to the Inspector and later send a written statement in the prescribed form within twentyfour hours of sending the telegraphic report."

(3) in sub-rule (3) of rule 61 for the existing proviso the following provisos shall be substituted, namely:—

"Provided that where the supply is at low voltage, this sub-rule shall not apply to isolated wall tabs or to brackets, electroliers switches, ceiling fans or other fittings (other than portable hand lamps and portable and transportable apparatus unless provided with earth terminal

Provided further that where the supply is at low voltage and where the installations are either new or renovated all plug

sockets shall be of the three pin type, and the third pin shall be permanently and efficiently earthed.";

(4) after Annexure XII the following Annexure shall be inserted, namely :—

"ANNEXURE XIII

FORM FOR REPORTING ELECTRICAL ACCIDENTS

(*See* rule 44 A)

1. Date and time of accident.

2. Place of Accident, and district.

3. System and voltage of supply.

4. Name of the Licensee or person/persons or supplier or user of energy in whose premises or jurisidiction the accident occurred.

5. (*a*) (i) Name of person (ii) Animal (Please specify the name and address of the owner).

Names of persons.

Killed or injured.

(*b*) Address of such/each persons.

6. Occupation and designation of such person/persons (and in particular whether employed in electrical works or elsewhere).

7. Brief description of the job undertaken, if any.

8. Authority under which such person/persons was/were allowed to work on the job.

State also whether he/they was/were authorised person/persons.

9 Describe fully nature and extent of injuries, *e. g.*, fatal disabelment of any portion of body or other injury, etc.

10, Detailed causes leading to the accident.

11. Action taken regarding First Aid, medical attendance, etc., immediately after the occurrence of the accident.

12. Whether appropriate Government District Magistrate and Police Station informed (if so give the address).

13. Steps taken to preserve the evidence in connection with the accident, to the extent possible.

14. Name and Designation/s of the person/s assisting the person/s killed or injured.

15 What safety equipment were given to and used by the person/s when met with this accident (*e.g.* rubber gloves, rubber mats, safety belts and ladders etc.).

16. Whether isolating switches and other sectionalising devices were employed to deaden the sections for working on the same, if so, whether these were earthed.

17. Whether the work on live lines was undertaken under the direct supervision of Authorised person. If so, the name and designation of the person under whose supervision the work was being carried out.

18. Whether artificial resuscitation treatment was given to the person who met with electric accident. If yes, for how long was it continued, before its abandonment.

19. Steps proposed to be taken to avoid recurrence.

20. Names and designations of persons present at the time of accident.

21. Any other remarks.

Signature
Name
Designation/occupation
Address of the person reporting.

DATE.
Time.

[No. EL-II-8 (8)/65.]

D. K. BASU,
Secy., Central Electricity Board